

Ведомость учета расхода воды
за период с 23.07.2025 по 23.08.2025

Потребитель: ООО МастерАдрес объекта: Громовой 105 (первая очередь)МКТС: № 002611-2Версия МКТС: 2.42

Дата	Трубопровод № 1				Трубопровод № 2				Трубопровод № 3			
	Объем V1, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V2, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V3, м3	Темп. °C	Давл. ати	Вр.раб час
23.07.25	82.75	60.9	4.0	24.00	74.44	55.5	4.0	24.00	0.00	---	---	0.00
24.07.25	82.34	60.9	4.0	24.00	74.45	55.5	4.0	24.00	0.00	---	---	0.00
25.07.25	83.09	61.0	4.0	24.00	74.86	55.6	4.0	24.00	0.00	---	---	0.00
26.07.25	85.69	61.0	4.0	24.00	77.19	55.8	4.0	24.00	0.00	---	---	0.00
27.07.25	82.19	61.0	4.0	24.00	74.06	55.6	4.0	24.00	0.00	---	---	0.00
28.07.25	82.56	61.0	4.0	24.00	74.03	55.5	4.0	24.00	0.00	---	---	0.00
29.07.25	82.75	60.9	4.0	24.00	73.89	55.4	4.0	24.00	0.00	---	---	0.00
30.07.25	82.19	60.9	4.0	24.00	73.81	55.4	4.0	24.00	0.00	---	---	0.00
31.07.25	81.97	60.9	4.0	24.00	73.84	55.4	4.0	24.00	0.00	---	---	0.00
01.08.25	81.81	60.9	4.0	24.00	73.75	55.4	4.0	24.00	0.00	---	---	0.00
02.08.25	81.88	60.9	4.0	24.00	73.61	55.2	4.0	24.00	0.00	---	---	0.00
03.08.25	82.28	61.0	4.0	24.00	73.34	55.3	4.0	24.00	0.00	---	---	0.00
04.08.25	81.66	60.9	4.0	24.00	73.61	55.3	4.0	24.00	0.00	---	---	0.00
05.08.25	81.69	60.9	4.0	24.00	73.66	55.1	4.0	24.00	0.00	---	---	0.00
06.08.25	82.44	60.9	4.0	24.00	73.53	55.1	4.0	24.00	0.00	---	---	0.00
07.08.25	81.94	60.9	4.0	24.00	73.59	55.2	4.0	24.00	0.00	---	---	0.00
08.08.25	81.38	60.9	4.0	24.00	73.89	55.2	4.0	24.00	0.00	---	---	0.00
09.08.25	81.72	60.9	4.0	24.00	73.53	55.2	4.0	24.00	0.00	---	---	0.00
10.08.25	82.00	60.9	4.0	24.00	73.73	55.2	4.0	24.00	0.00	---	---	0.00
11.08.25	77.88	60.8	4.0	24.00	70.47	55.0	4.0	24.00	0.00	---	---	0.00
12.08.25	83.34	60.9	4.0	24.00	74.05	55.1	4.0	24.00	0.00	---	---	0.00
13.08.25	85.16	61.0	4.0	24.00	76.67	55.3	4.0	24.00	0.00	---	---	0.00
14.08.25	84.78	61.0	4.0	24.00	76.89	55.4	4.0	24.00	0.00	---	---	0.00
15.08.25	84.50	61.0	4.0	24.00	76.89	55.5	4.0	24.00	0.00	---	---	0.00
16.08.25	84.56	60.9	4.0	24.00	76.67	55.5	4.0	24.00	0.00	---	---	0.00
17.08.25	85.78	61.0	4.0	24.00	75.13	55.5	4.0	24.00	0.00	---	---	0.00
18.08.25	85.31	61.0	4.0	24.00	77.27	55.4	4.0	24.00	0.00	---	---	0.00
19.08.25	85.63	61.0	4.0	24.00	76.72	55.4	4.0	24.00	0.00	---	---	0.00
20.08.25	84.78	60.9	4.0	24.00	76.86	55.3	4.0	24.00	0.00	---	---	0.00
21.08.25	84.94	60.9	4.0	24.00	76.66	55.3	4.0	24.00	0.00	---	---	0.00
22.08.25	85.75	60.9	4.0	24.00	76.41	54.9	4.0	24.00	0.00	---	---	0.00
23.08.25	86.59	60.0	4.0	24.00	75.69	54.5	4.0	24.00	0.00	---	---	0.00
Итого:	2663.31	60.9	4.0	768.00	2393.19	55.3	4.0	768.00	0.00	---	---	0.00

Показания МКТС (нарастающим итогом)

Дата	Объем V1, м3	Траб V1, ч	Объем V2, м3	Траб V2, ч	Объем V3, м3	Траб V3, ч
23.08.25 24:00	290732.25	112441.60	245879.33	112441.60	0.00	0.00
22.07.25 24:00	288068.94	111673.61	243486.14	111673.61	0.00	0.00
Итого:	2663.31	768.00	2393.19	768.00	0.00	0.00

Отчетный период: 768.00 чВремя откл. эл.-питания: 0.00 чВремя работы V1: 768.00 чВремя неисправности V1: 0.00 чВремя работы V2: 768.00 чВремя неисправности V2: 0.00 чВремя работы V3: 0.00 чВремя неисправности V3: 768.00 чПредставитель
потребителя:Представитель
поставщика:Распечатано программой MktsPrint, версия 1.31