

Ведомость учета расхода воды
за период с 23.08.2025 по 23.09.2025

Потребитель: **ООО Мастер**Адрес объекта: **Громовой 105 (первая очередь)**МКТС: **№ 002611-2**Версия МКТС: **2.42**

Дата	Трубопровод № 1				Трубопровод № 2				Трубопровод № 3			
	Объем V1, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V2, м3	Темп. °C	Давл. ати	Вр.раб час	Объем V3, м3	Темп. °C	Давл. ати	Вр.раб час
23.08.25	86.59	60.0	4.0	24.00	75.69	54.5	4.0	24.00	0.00	---	---	0.00
24.08.25	84.69	37.4	4.0	24.00	74.67	35.7	4.0	24.00	0.00	---	---	0.00
25.08.25	82.94	27.3	4.0	24.00	74.45	26.6	4.0	24.00	0.00	---	---	0.00
26.08.25	84.16	25.1	4.0	24.00	76.42	24.7	4.0	24.00	0.00	---	---	0.00
27.08.25	85.34	23.9	4.0	24.00	78.20	23.7	4.0	24.00	0.00	---	---	0.00
28.08.25	84.75	23.0	4.0	24.00	78.19	22.8	4.0	24.00	0.00	---	---	0.00
29.08.25	85.72	30.1	4.0	24.00	78.13	28.5	4.0	24.00	0.00	---	---	0.00
30.08.25	89.03	60.4	4.0	24.00	78.78	54.7	4.0	24.00	0.00	---	---	0.00
31.08.25	86.84	60.9	4.0	24.00	77.14	55.2	4.0	24.00	0.00	---	---	0.00
01.09.25	84.50	60.9	4.0	24.00	75.78	55.2	4.0	24.00	0.00	---	---	0.00
02.09.25	84.22	60.7	4.0	24.00	75.08	55.0	4.0	24.00	0.00	---	---	0.00
03.09.25	83.28	60.9	4.0	24.00	75.11	55.2	4.0	24.00	0.00	---	---	0.00
04.09.25	82.84	60.9	4.0	24.00	75.02	55.3	4.0	24.00	0.00	---	---	0.00
05.09.25	83.84	60.9	4.0	24.00	74.70	55.3	4.0	24.00	0.00	---	---	0.00
06.09.25	84.28	60.9	4.0	24.00	74.53	55.3	4.0	24.00	0.00	---	---	0.00
07.09.25	83.78	60.9	4.0	24.00	74.98	55.3	4.0	24.00	0.00	---	---	0.00
08.09.25	83.50	60.9	4.0	24.00	75.06	55.2	4.0	24.00	0.00	---	---	0.00
09.09.25	83.91	60.9	4.0	24.00	75.11	55.2	4.0	24.00	0.00	---	---	0.00
10.09.25	83.81	60.9	4.0	24.00	75.14	55.2	4.0	24.00	0.00	---	---	0.00
11.09.25	83.97	60.8	4.0	24.00	75.23	55.1	4.0	24.00	0.00	---	---	0.00
12.09.25	83.84	60.8	4.0	24.00	74.95	55.1	4.0	24.00	0.00	---	---	0.00
13.09.25	84.25	60.8	4.0	24.00	74.59	55.1	4.0	24.00	0.00	---	---	0.00
14.09.25	84.13	60.8	4.0	24.00	74.97	55.1	4.0	24.00	0.00	---	---	0.00
15.09.25	83.88	60.8	4.0	24.00	75.27	55.0	4.0	24.00	0.00	---	---	0.00
16.09.25	84.53	60.8	4.0	24.00	75.11	55.0	4.0	24.00	0.00	---	---	0.00
17.09.25	82.97	60.8	4.0	24.00	72.25	54.9	4.0	24.00	0.00	---	---	0.00
18.09.25	86.47	60.9	4.0	24.00	76.64	55.1	4.0	24.00	0.00	---	---	0.00
19.09.25	85.31	60.9	4.0	24.00	76.27	55.2	4.0	24.00	0.00	---	---	0.00
20.09.25	85.16	60.9	4.0	24.00	76.00	55.3	4.0	24.00	0.00	---	---	0.00
21.09.25	85.38	60.9	4.0	24.00	75.83	55.2	4.0	24.00	0.00	---	---	0.00
22.09.25	85.03	60.8	4.0	24.00	75.88	55.0	4.0	24.00	0.00	---	---	0.00
23.09.25	85.09	60.8	4.0	24.00	75.77	54.9	4.0	24.00	0.00	---	---	0.00
Итого:	2708.03	54.5	4.0	768.00	2420.94	49.7	4.0	768.00	0.00	---	---	0.00

Показания МКТС (нарастающим итогом)

Дата	Объем V1, м3	Траб V1, ч	Объем V2, м3	Траб V2, ч	Объем V3, м3	Траб V3, ч
23.09.25 24:00	293353.69	113185.60	248224.58	113185.60	0.00	0.00
22.08.25 24:00	290645.66	112417.60	245803.64	112417.60	0.00	0.00
Итого:	2708.03	768.00	2420.94	768.00	0.00	0.00

Отчетный период: **768.00 ч**Время откл. эл.-питания: **0.00 ч**Время работы V1: **768.00 ч**Время неисправности V1: **0.00 ч**Время работы V2: **768.00 ч**Время неисправности V2: **0.00 ч**Время работы V3: **0.00 ч**Время неисправности V3: **768.00 ч**Представитель
потребителя:Представитель
поставщика:Распечатано программой МКТСП.ИИ, версия: **1.31**